



水務監督辦事處
Office of the Water Authority

香港灣仔告士打道七號入境事務大樓
Immigration Tower, 7 Gloucester Road, Hong Kong.

電子郵遞
e-mail wsdinfo@wsd.gov.hk

電話
Telephone 2829 4367

圖文傳真
Facsimile 2824 0578

檔號
Reference (3) in WSD 3611/11/96 Pt.5 T/J(14)

26 October 2004

Fabri-Technic Engineering & Trading Co. Ltd.
17 Floor, Wing Wah Ind. Bldg.,
677 King's Road,
North Point,
H.K.
(Attn.: Ms. Fannie CHAN)

Dear Sirs,

**Permission for Connection to a Main
"FILTEK" Instant Boiling Water Heaters
Models No.: WB-15, WB-35 & WB-50**


Your letters dated 26 July 2004 refers.

After examining the technical information, it is considered from water supply point of view that the captioned instant boiling water heaters are suitable for use with off-tank or direct connection to waterworks mains. However, you are required to ensure that these water heaters should also comply with the requirements of Electrical & Mechanical Services Department.

Installation of the heater must be in full compliance with the conditions stipulated in Part IV of Schedule 2 of Waterworks Regulations, Chapter 102. Your particular attention is drawn to that the heater is required to have a guaranteed test pressure of at least 1.5 times the static head available at the heater.

This letter should not be regarded as a certification/approval on the construction, quality, durability, efficiency etc. of the water heater as these aspects should remain to be the manufacturer's guarantee. The acceptance given by this letter will be withdrawn if the water heaters are found to be unsuitable for use in fresh water plumbing systems.

Yours faithfully,


(CHIN Chu Sum)
for Water Authority